Wentwood Mill Earlswood

BETA This is a new service – your <u>feedback</u> will help us to improve it.

< <u>Back</u>

Energy performance certificate (EPC)

Chepstow

NP16 5QH

Certificate contents

- Rules on letting this property Energy performance rating for this property — Breakdown of property's energy
- performance - Environmental impact of this
- property How to improve this property's
- energy performance — Estimated energy use and
- potential savings - Contacting the assessor and accreditation scheme
- Other certificates for this

G Certificate number Valid until 7 June 2031 0500-2008-0060-2009-4045 Detached house **Property type** 102 square metres Total floor area

Energy rating

Share this certificate

🖂 Email

property

- 🖞 Copy link
- ම් Print

Rules on letting this property


- You may not be able to let this property
 - This property has an energy rating of G. It cannot be let, unless an exemption has been registered. You can read guidance for landlords on the regulations and exemptions.

Properties can be rented if they have an energy rating from A to E. The recommendations section sets out changes you can make to improve the property's rating.

Energy efficiency rating for this property

This property's current energy rating is G. It has the potential to be C.

See how to improve this property's energy performance.



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

• the average energy rating is D • the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

• very good (most efficient)

• good

average

• poor • very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Sandstone or limestone, as built, no insulation	Very
	(assumed)	poor
Roof	Pitched, no insulation (assumed)	Very
		poor
Window	Single glazed	Very
		poor
Main heating	Boiler and radiators, coal	Poor
Main heating	No time or thermostatic control of room	Very
control	temperature	poor
Hot water	From main system, no cylinder thermostat	Very
		poor
Lighting	Low energy lighting in 50% of fixed outlets	Good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 716 kilowatt hours per square metre (kWh/m2).

What is primary energy use?

Environmental impact of this property


One of the biggest contributors to climate change is carbon dioxide (CO2). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO2 emissions.

An average household produces	6 tonnes of CO2
This property produces	28.0 tonnes of CO2
This property's potential production	9.7 tonnes of CO2

By making the <u>recommended changes</u>, you could reduce this property's CO2 emissions by 18.3 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

How to improve this property's energy performance



Internal or external wall insulation

Typical installation cost	£4,000-£14,000
Typical yearly saving	£864
Potential rating after carrying out recommendation 1	24 F

Recommendation 2: Floor insulation (solid floor)

Floor insulation (solid floor)

Typical installation cost	£4,000-£6,000
Typical yearly saving	£107
Potential rating after carrying out recommendations 1 and 2	27 F

Recommendation 3: Draught proofing

Draught proofing

Typical installation cost	£80-£120
Typical yearly saving	£72
Potential rating after carrying out recommendations 1 to 3	28 F

Recommendation 4: Low energy lighting

Low energy lighting

Typical installation cost	£20
Typical yearly saving	£29
Potential rating after carrying out recommendations 1 to 4	29 F

Recommendation 5: Heating controls (programmer, room thermostat and TRVs)

Heating controls (programmer, thermostat, TRVs)

Typical installation cost	£350-£450
Typical yearly saving	£209
Potential rating after carrying out recommendations 1 to 5	34 F

Recommendation 6: Solar water heating

Solar water heating

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£278
Potential rating after carrying out recommendations 1 to 6	42 E

Recommendation 7: Double glazed windows

Replace single glazed windows with low-E double glazed windows

Typical installation cost	£3,300-£6,500
Typical yearly saving	£173
Potential rating after carrying out recommendations 1 to 7	48 E

Recommendation 8: Solar photovoltaic panels, 2.5 kWp

Solar photovoltaic panels

Typical installation cost	£3,500-£5,500
Typical yearly saving	£354
Potential rating after carrying out recommendations 1 to 8	57 D

Recommendation 9: Wind turbine

Wind turbine

Typical installation cost	£15,000 - £25,000
Typical yearly saving	£676
Potential rating after carrying out recommendations 1 to 9	76 C

Paying for energy improvements

Find energy grants and ways to save energy in your home.

Estimated energy use and potential savings

Estimated yearly energy cost for this property	£3181
Potential saving	£1733

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in <u>how</u> to improve this property's energy performance.

For advice on how to reduce your energy bills visit <u>Simple Energy Advice</u>.

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Space heating	25789 kWh per year
Water heating	5971 kWh per year

Potential energy savings by installing insulation

Amount of energy saved
4667 kWh per year
10056 kWh per year

You might be able to receive <u>Renewable Heat Incentive payments</u>. This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Michael Forrest
Telephone	07375040715
Email	mikeforrest907@gmail.com

Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO016154
Telephone	03301249660
Email	certification@stroma.com

Assessment details

Assessor's declaration	No related party
Date of assessment	8 June 2021
Date of certificate	8 June 2021
Type of assessment	► <u>RdSAP</u>

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at <u>mhclg.digital-services@communities.gov.uk</u> or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.



© Crown copyright

Accessibility statement Cookies on our service